



The **CITY OF HENDERSON PWS 2010001** has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems that use a series of treatment processes that includes coagulation, flocculation, sedimentation or clarification, and filtration as part of the overall treatment protocol must monitor Total Organic Carbon and report the results of that monitoring to the TCEQ on a monthly basis.

We failed to monitor and/or report the following constituents: **CARBON, TOTAL**
This/These violation(s) occurred in the monitoring period(s) **JULY 2021**

Results of monitoring are an indicator of whether drinking water is protected from potential adverse health effects associated with disinfectants and disinfection by-products. We did not complete all monitoring and/or reporting for disinfectant by-product precursors, and therefore TCEQ cannot be sure of the Total Organic Carbon levels in your drinking water during that time.

We are taking the following actions to address this issue:

Sampling will be collected at least twice a month the first week and the third week of the month

<corrective actions>

Total organic carbon (TOC) is the amount of [carbon](#) found in an [organic compound](#) and is often used as a non-specific indicator of [water quality](#) or cleanliness of pharmaceutical manufacturing equipment. TOC may also refer to the amount of organic carbon in [soil](#), or in a [geological formation](#).

If you have questions regarding this matter, you may contact:

Water System Official: Randy Boyd

Area code + phone number: (903) 657-5246

Posted date /Delivered on: May 15 and June 1 water billing dates
